

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHEK/C/7049

Dated: 09-02-2026

It is certified that an inspection team headed by Sandeep Kumar CAEE

(Name of Officers with designation) from PHE SUB-Division Hisonagar

inspected the Delhi Public School

(Name & Address of the school) on 05-02-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 7(B) dated 07-02-2026

of District Water Testing Lab. Labhampur (Kathua) (PHED Lab) certified that the

Delhi Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till March 2027

Signature with Seal: Executive Engineer

Name: Jal Shakti (PHE) Division

Designation: Sumesh Kathua

Name & Address of the Office / Department: Executive Engineer
PHE Division
Kathua

To Delhi Public School
Kathua

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

	DISTRICT WATER TESTING LABORATORY, LAKHANPUR, KATHUA JAL SHAKTI (PHE) DEPARTMENT, KATHUA, UT OF J&K DOC Ref: PHE/WQC/DLK/QF-7.8-01		

TEST REPORT

Customer Name:	Principal, Delhi Public School, Kathua		
Sample Quantity:	1.5 Litre	Sample Container Condition:	OK / Not Satisfactory
Sample ID:	DLK1021WQ7(B)	Date of Receipt:	05-02-2026
Report No:	7(B)	Report Date:	07-02-2026.
Sample Details:	Delhi Public School, Kathua.		Source: Borewell
Test Start Date:	05-02-2026	Test End Date:	07-02-2026.
Sample Collected by	Self.		

Sr. No.	Parameter	BIS Permissible Limit	Unit	Test Results	Remarks
1.	pH	6.5-8.5	--	6.59	Fit/ Unfit
2.	Colour	15	HU	10	Fit/ Unfit
3.	TDS	2000	mg/l	270	Fit/ Unfit
4.	Turbidity	5	NTU	1.80	Fit/ Unfit
5.	Iron	1.0	mg/l	0.0217	Fit/ Unfit
6.	Chloride	1000	mg/l	14.99	Fit/ Unfit
7.	Magnesium	100	mg/l	6.30	Fit/ Unfit
8.	Sulphate	400	mg/l	11.47	Fit/ Unfit
9.	Calcium	200	mg/l	16.032	Fit/ Unfit
10.	Total Hardness	600	mg/l	66	Fit/ Unfit
11.	Alkalinity	600	mg/l	70	Fit/ Unfit
12.	Flouride	1.5	mg/l	0.0	Fit/ Unfit
13.	Residual Chlorine	1.0	mg/l	nil.	Fit/ Unfit
BACTERIOLOGICAL QUALITY PARAMETERS					
1.	E. Coli	Absent/ 100ml	Absent/ 100ml	ABSENT	Present/ Absent

Note:
1. The test report and result relate to the material's specimen/ sample (s) as delivered /received and tested in the laboratory. **2.** This test report shall not be reproduced in part, without the permission of this laboratory. **3.** Any correction invalidates this test report. **4.** WQC lab always strives to provide accurate and reliable for all customers. **5.** However, it is not responsible for any financial/ legal liability arising out of any errors or omissions. **6.** The report has been presented in a simplified manner and the test conditions will be available on request. **7.** Results apply to the sample as received.

Authorised Signatory


Mrs Monika Sharma
 (Designation: Quality Manager)

End of Report

